

Map ID
Direction
Distance
Elevation

MAP FINDINGS

EDR ID Number
EPA ID Number

295
WNW
1/4-1/2
0.434 mi.
2289 ft.

2955 CROPSEY AVE/GETTY
2955 CROPSEY AVENUE
NEW YORK CITY, NY

NY LTANKS S100145277
N/A

Relative:
Higher

Actual:
14 ft.

LTANKS:

Name: 2955 CROPSEY AVE/GETTY
Address: 2955 CROPSEY AVENUE
City,State,Zip: NEW YORK CITY, NY
Spill Number/Closed Date: 8806804 / 1992-07-16
Facility ID: 8806804
Site ID: 127937
Spill Date: 1988-11-11
Spill Cause: Tank Test Failure
Spill Source: Gasoline Station or other PBS Facility
Spill Class: B3
Cleanup Ceased: 1992-07-16
SWIS: 2401
Investigator: SULLIVAN
Referred To: Not reported
Reported to Dept: 1988-11-15
CID: Not reported
Water Affected: Not reported
Spill Notifier: Tank Tester

Last Inspection: Not reported
Recommended Penalty: False
Meets Standard: True
UST Involvement: True
Remediation Phase: 0
Date Entered In Computer: 1988-11-18
Spill Record Last Update: 1992-07-28
Spiller Name: Not reported
Spiller Company: GETTY GAS STATION
Spiller Address: 2955 CROPSEY AVENUE
Spiller County: 001
Spiller Contact: Not reported
Spiller Phone: Not reported
Spiller Extention: Not reported
DEC Region: 2
DER Facility ID: 284190
DEC Memo: ""
Remarks: "4K TANK FAILED PETRO TITE WITH A LEAK RATE OF -.129GPH, WILL EXCAVATE AND ISOLATE TANK."

All TTF:

Facility ID: 8806804
Spill Number: 8806804
Spill Tank Test: 1534891
Site ID: 127937
Tank Number: Not reported
Tank Size: 0
Material: 0009
EPA UST: Not reported
UST: Not reported
Cause: Not reported
Source: Not reported
Test Method: 00
Test Method 2: Unknown
Leak Rate: .00

Map ID
Direction
Distance
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number
EPA ID Number

Gross Fail: Not reported
Modified By: Spills
Last Modified Date: Not reported

All Materials:

Site ID: 127937
Operable Unit ID: 923627
Operable Unit: 01
Material ID: 455145
Material Code: 0009
Material Name: gasoline
Case No.: Not reported
Material FA: Petroleum
Quantity: -1.00
Units: Not reported
Recovered: .00
Oxygenate: Not reported